

HANGING ILLUMINATED EXIT SIGN



Code	Finish	Legend Format	Operation	Size (mm)	Viewing distance (m)	Integral Test Routine	Battery Recharge Period
SHPW/M/3W/MT/EC/**	White	EC Signs Directive	Maintained	355x216x112	28m viewing	Manual Test	< 24 hours
SHPW/M/3W/DST/EC/**	White	EC Signs Directive	Maintained	355x216x112	28m viewing	EN62034/DALI	< 24 hours
SHPW/M/3W/MT/ISO/**	White	ISO 7010	Maintained	355x216x112	28m viewing	Manual Test	< 24 hours
SHPW/M/3W/DST/ISO/**	White	ISO 7010	Maintained	355x216x112	28m viewing	EN62034/DALI	< 24 hours

- See website for LDT files
- For CAD/BIM contact us
- See website for Technical Data Sheet
- DALI/Self Test luminaire will operate in self test mode if no DALI signal is detected
- For Silver version, replace W in part number with S, e.g SHPS/M/...
- Self test products automatically randomise their testing times for minimal risk, tests can occur at any time. This should be considered when designing projects.
- Replace ** with required legend:

AR = Arrow Right
 AL = Arrow Left
 AD = Arrow Down
 AU = Arrow Up

- Please specify a mounting bracket or suspension kit per fitting when ordering.

SHP/CBRK/W = Ceiling Mounting Bracket White
 SHP/CBRK/S = Ceiling Mounting Bracket Silver
 SHP/SUSP = Suspension Kit
 SHP/WBRK/W = Wall Mounting Bracket White
 SHP/WBRK/S = Wall Mounting Bracket Silver
 SHP/EBRK/W = End Fixing Flag Bracket White
 SHP/EBRK/S = End Fixing Flag Bracket Silver

