



Code	Finish	Legend Format	Operation	Size (mm)	Viewing distance (m)	Integral Test Routine	Battery Recharge Period
<b>BLKW/M/3W/MT/EC/**</b>	White	EC Signs Directive	Maintained	355x216x112	28 viewing	Manual Test	< 24 hours
<b>BLKW/M/3W/DST/EC/**</b>	White	EC Signs Directive	Maintained	355x216x112	28 viewing	EN62034/DALI	< 24 hours
<b>BLKW/M/3W/MT/ISO/**</b>	White	ISO 7010	Maintained	355x216x112	28 viewing	Manual Test	< 24 hours
<b>BLKW/M/3W/DST/ISO/**</b>	White	ISO 7010	Maintained	355x216x112	28 viewing	EN62034/DALI	< 24 hours

- See website for LDT files
- For CAD/BIM contact us
- See website for Technical Data Sheet
- DALI/Self Test luminaire will operate in self test mode if no DALI signal is detected
- Self test products automatically randomise their testing times for minimal risk, tests can occur at any time. This should be considered when designing projects.

• Replace \*\* with required legend:

- AR = Arrow Right
- AL = Arrow Left
- AD = Arrow Down
- AU = Arrow Up

